



OFFICE OF THE DEPUTY FIRE OFFICER,
CUTTACK CIRCLE,
BUXI BAZAR, CUTTACK, 753001

FORM-V
FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha fire Prevention and Fire Safety Rules 2017 r/w Odisha Fire Prevention and Fire Safety (Amendment) Rules ,2019.)

File No. X-2-B-95-2023

Certificate No 168 /CR.CTC

dated: 30.05.2023

This Certificate is valid up to 29.05.2026

(Apply for renewal at least three months before expiry)


Certified that Dadhichi Public School, over plot No.- 3/515, Khata No.- 83/61 Mouza- Deuli, At - Vidya Vihar, po- Sundargaram, Ps- Oltopur, Cuttack consisting of total 01 no. building was inspected by Officers of the fire service on 25.05.2023 in presence of Dr. Manoj Kumar Dash, Chairman with team and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha fire prevention and fire safety rules-2017 read with Fire prevention and Fire Safety (Amendment) Rules-2019 and Odisha Fire Service one time relaxation scheme published vide Govt. of Odisha Home Department Notification No.28550/CD,Bhubaneswar,dt.28.08.2020 and that its various floors are fit for occupancy or usages as noted hereunder against each subject to compliance to the conditions as prescribed herein below.

01	Ground, 1 st & 2 nd floor	---Usage---	Educational (School)
----	---	-------------	-------------------------

CONDITIONS:


1. Fire prevention and safety measures and appliances, availability of water supplies and means of access there to etc provide in the building or premises, should be maintained by the occupier(s) in best repairs and efficient working conditions at all times for use by the occupants or the members of the fire service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exists, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupiers(s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/rehearsals should be organized at least once in six months by involving local Fire Station.
5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in floors of building/ premises.
6. The plan needs to be regularized/ approved by the competent plan approving authority of the jurisdiction as per Govt. Of Odisha Home Department notification No.28550/CD, Bhubaneswar, dt.28.08.2020 Regarding one time relation scheme for Odisha Fire Service on requirement of structural Fire Safety parameters.
7. All other conditions furnished in Odisha Fire Service one time relaxation scheme published vide Govt. of Odisha Home Department Notification No. 28550/CD, Bhubaneswar, dt.28.08.2020 will be applicable to this occupancy and applicant will comply an each plant accordingly.
8. Tis fire safeties Certificate do not absolve provision made in any other rules and will not automatically immune the provisions mode therein.

By order of the Director of Fire Service


dt 30.05.23
(T.K. Sahoo)
Deputy Fire Officer
Cuttack Circle, Cuttack

Memo no- 0458 /CD. CTC.

Copy to Principal, Dadhichi College of Pharmacy under Dadhichi Educational Trust, At - Vidya Vihar, po- Sundargaram, Ps- Oltopur, Cuttack. For information and necessary action from your end.


dt 30.05.23
(T.K. Sahoo)
Deputy Fire Officer
Cuttack Circle, Cuttack